

**Customer:** Evergreen Elementary

**Location:** Tacoma, WA 98433

**Time & Duration:** 1 Week

Reference: Evergreen Elementary 16499



### Job Description:

Inspect site and ensure proper installation of SEM3 Controller, PAC4200 Meters, Siemens Touch PC and LonWorks communication gateway.

### INP Task

- Installation of WINPM.NET 7.0 on touch Panel PC.
- Commissioning of LONWORKS Gateway to communicate with the Building Automation System of the School.
- Configuration and Set Up of Sem3 Meter Modules.
- Train Customer on WinPM.Net usage and report generation.
- Ensure communication between devices and BAS.

### Conclusion

- Power Monitoring System installed on Touch Panel and able to retrieve and display data from Meters.
- BAS able to communicate with devices and to retrieve data.
- Customer is able to manipulate Power Monitoring system and to generate reports.

---

#### MEXICO

INP Mexico S.A de C.V  
Fray Junipero Serra #2450  
Suite 501  
Pabellón Cooperativo Juriquilla  
76230 Queretaro  
Mexico

Tel. +52 442 3930703  
mexico@inp-e.com

#### USA

INP North America Inc.  
11390 Old Roswell Rd.  
Suite 126  
Alpharetta, GA 30009  
USA

Tel. +1 678 527-1400  
Fax +1 678 527-1410  
us@inp-e.com

#### CANADA

INP Canada Inc.  
2275 Upper Middle Rd E  
Suite 101  
Oakville, Ontario L6H 0C3  
Canada

Tel. +1 289 291-5264  
canada@inp-e.com